

Accelerated Capital Allowances Eligibility Criteria

Category: Heating and Electricity Provision**Technology: Hot Water Generation**

Hot Water Generation is defined as advanced equipment which provides heating and/or hot water primarily for on-site use.

Hot Water Generation equipment is considered to include the following:

Direct Hot Water Heaters

Direct Hot Water Heaters combust fuel to provide hot water on demand, whereby the water used is heated directly by the boiler. They also have the facility to recover heat from the flue gases to maximise the heat output from the boiler.

Closed Loop Hot Water Heaters

Closed Loop Hot Water Heaters combust fuel to provide heating, whereby the delivery medium is a closed loop hot water system which can also indirectly heat water for on-site use. The equipment consists of the boiler and/or burner.

Eligibility Criteria Overview

In order to be included on the ACA Specified List, the specific Hot Water Generation equipment must meet *all* of the relevant requirements set out below.

Note: *Supporting documentation that clearly demonstrates ACA compliance according to the conditions below will be required as part of the ACA checking process. Detailed information on the types of documents accepted can be found in the separate Supporting Documentation guidelines.*

General Eligibility Criteria

(Applicable to all Hot Water Generation equipment)

No.	Condition
1.	Condensing only.
2.	All equipment and/or components must be CE marked as required by the specific EU directive(s).

Direct Hot Water Heaters specific Eligibility Criteria:

(To be met in addition to the general eligibility criteria)

No.	Condition
3.	Net Thermal Efficiency tested at full load: <ul style="list-style-type: none"> • Storage & non-storage instantaneous types must be $\geq 102\%$ • Non storage circulator types must be $\geq 93\%$

4.	<ul style="list-style-type: none"> ▪ Gas condensing water heaters must comply with all the requirements in the standard EN 89 “Gas-fired storage water heaters for the production of domestic hot water”, or scientific equivalent. ▪ Gas condensing water heaters with atmospheric burners must comply with EN 26/A1 “Gas-fired instantaneous water heaters for sanitary uses production, fitted with atmospheric burners (Including Corrigendum 1998)”, or scientific equivalent.
5.	Modulating output – non-storage types must have the capability to vary their hot water output in response to changes in water demand, without initiating a purge cycle.
6.	Balanced flue on units with a rated output less than 70kW.

Closed Loop Hot Water Heaters specific Eligibility Criteria:

(To be met in addition to the general eligibility criteria)

No.	Condition
7.	<p>Boilers <70kW rated output Seasonal Thermal Efficiency must be $\geq 93\%$ (To be calculated according to S.I. No. 260/1994 as used in the Home-heating Appliance Register of Performance (HARP) database)</p> <p>or</p> <p>Boilers >70kW rated output Net Thermal Efficiency $\geq 93\%$ (To be calculated as per - UK DTI Efficiency Requirements for Hot-water Boilers, Oct 1995)</p>
8.	<p>Must be tested in accordance with BS 845: Part 1 ‘Methods for assessing thermal performance of boilers for steam, hot water and high temperature heat transfer fluids – Part 1 Concise Procedure’, or scientific equivalent.</p> <p>and</p> <ul style="list-style-type: none"> ▪ Oil boilers must be tested in accordance with EN 304 “Heating boilers – Test code for heating boiler for atomising oil burners”, or scientific equivalent. ▪ Oil & gas shell boilers must comply with the acceptance tests set out in EN 12953-11 “Shell Boilers – Part 11: Acceptance tests”, or scientific equivalent. ▪ Oil & gas water tube boilers must comply with the acceptance tests set out in EN 12952-15 “Water-tube boilers and auxiliary installations. Acceptance tests”, or scientific equivalent. ▪ Combination boilers must also comply with “EN 625-Gas-fired central heating boilers – Specific requirements for the domestic hot water operation of combination boilers of nominal heat input not exceeding 70 kW”, or scientific equivalent.
9.	Incorporated burners must comply with part 19 “Boiler Controls” eligibility criteria.
10.	Standing losses – 2% or less of boiler rated output.

----- End of ACA eligibility criteria -----
Please see next section for technical detail submission and supporting documentation guidance

The following information is not part of the official criteria document published within the relevant statutory Instrument; it has been added here for guidance purposes only in order to provide assistance with the submission of product details and the provision of the required supporting documentation.

Note: All information contained within this guidance document is subject to change without notice

Technical information required in product submission

The following are the specific technical values required as part of the product submission for this technology:

Hot water generation product type

As part of the product submission you must first select which type of hot water generation system your product is. Only one type can be chosen per product.

Thermal output

The thermal output in kW of the hot water generation product is required as a value for the product submission. It must be entered as whole number only (do not include kW symbol). There should also be no spaces or full stops after the number submitted.

Thermal efficiency

The efficiency (%) of the hot water generation product is required as a value for the product submission. It must be entered as number only (do not include units). There should also be no spaces or full stops after the number submitted. The figure must comply with the criteria requirements for minimum efficiency values.

Supporting documentation required

Described below is the list of documents that are accepted as proof of compliance for the specific Hot Water Generation conditions.

Note: This information will only be requested **AFTER** you submit your product's basic details online

Important Notes to Product Providers

Please ensure that you read the "Important Notes to Product Providers" section at the end of this document prior to submitting documentation.

General Eligibility Criteria

(Applicable to all Hot Water Generation equipment)

No.	Condition	Supporting Documentation Requirement
1.	Condensing only.	Official and published manufacturer's technical data sheet or brochure that demonstrates the requirements of the condition.
2.	All equipment and/or components must be CE marked as required by the specific EU directive(s).	<p>Official and published manufacturer's technical data sheet or brochure that demonstrates CE marking compliance.</p> <p>OR</p> <p>A copy of an official signed declaration on headed paper which confirms CE marking compliance.</p> <p>Official declarations should explicitly state the product for which CE marking is being confirmed (i.e. do not provide a letter simply stating general compliance with the relevant ACA Condition).</p> <p>Where a document is used to demonstrate conformance for a number of products or range of products it should clearly specify each individual product covered by that document.</p>

Direct Hot Water Heaters specific Eligibility Criteria:

(To be met in addition to the general eligibility criteria)

No.	Condition	Supporting Documentation Requirement
3.	Net Thermal Efficiency tested at full load: <ul style="list-style-type: none"> •Storage & non-storage instantaneous types must be \geq 102% •Non storage circulator types must be \geq 93% 	Official and published manufacturer's technical data sheet or brochure that demonstrates the requirements of the condition.

No.	Condition	Supporting Documentation Requirement
4.	<ul style="list-style-type: none"> ▪ Gas condensing water heaters must comply with all the requirements in the standard EN 89 “Gas-fired storage water heaters for the production of domestic hot water”, or scientific equivalent. ▪ Gas condensing water heaters with atmospheric burners must comply with EN 26/A1 “ Gas-fired instantaneous water heaters for sanitary uses production, fitted with atmospheric burners (Including Corrigendum 1998)”, or scientific equivalent. 	<p><u>For gas condensing water heaters:</u> Accredited certification that the equipment complies with all the requirements of the named standard.</p> <p>OR Evidence of official testing by manufacturer or independent test lab carried out according to the principles outlined in the named standard. Test reports should be of the format described in the ‘Important Notes to Product Providers’ section of this document.</p> <p>Acceptable Standard: EN 89 “Gas Fired Storage Water Heaters for the production of domestic Hot Water”.</p> <p>See note on ‘Scientific Equivalence’ in the ‘Important Notes to Product Providers’ section at end of this document.</p> <p><u>For gas condensing water heaters with atmospheric burners:</u> Accredited certification that the equipment complies with the named standard.</p> <p>OR Evidence of official testing by manufacturer or independent test lab carried out according to the principles outlined in the named standard. Test reports should be of the format described in the ‘Important Notes to Product Providers’ section of this document.</p> <p>Acceptable Standard: EN 26/A1 “Gas-fired instantaneous water heaters for sanitary uses production, fitted with atmospheric burners (Including Corrigendum 1998)”.</p> <p>See note on ‘Scientific Equivalence’ in the ‘Important Notes to Product Providers’ section at end of this document.</p>
5.	Modulating output – non-storage types must have the capability to vary their hot water output in response to changes in water demand, without initiating a purge cycle.	Official and published manufacturer’s technical data sheet or brochure that demonstrates the requirements of the condition.
6.	Balanced flue on units with a rated output less than 70kW.	Official and published manufacturer’s technical data sheet or brochure that demonstrates the requirements of the condition.

Closed Loop Hot Water Heaters specific Eligibility Criteria:

(To be met in addition to the general eligibility criteria)

No.	Condition	Supporting Documentation Requirement
7.	<p>Boilers <70kW rated output Seasonal Thermal Efficiency must be $\geq 93\%$</p> <p>(To be calculated according to S.I. No. 260/1994 as used in the Home-heating Appliance Register of Performance (HARP) database)</p> <p>or</p> <p>Boilers >70kW rated output Net Thermal Efficiency $\geq 93\%$</p> <p>(To be calculated as per - UK DTI Efficiency Requirements for Hot-water Boilers, Oct 1995)</p>	<p>Official and published manufacturer's technical data sheet or brochure that demonstrates the requirements of the condition.</p>
8.	<p>Must be tested in accordance with BS 845: Part 1 'Methods for assessing thermal performance of boilers for steam, hot water and high temperature heat transfer fluids – Part 1 Concise Procedure', or scientific equivalent.</p> <p>and</p> <ul style="list-style-type: none"> ▪ Oil boilers must be tested in accordance with EN 304 "Heating boilers – Test code for heating boiler for atomising oil burners", or scientific equivalent. ▪ Oil & gas shell boilers must comply with the acceptance tests set out in EN 12953-11 "Shell Boilers – Part 11: Acceptance tests", or scientific equivalent. ▪ Oil & gas water tube boilers must comply with the acceptance tests set out in EN 12952-15 "Water-tube boilers and auxiliary installations. Acceptance tests", or scientific equivalent. ▪ Combination boilers must also comply with "EN 625-Gas-fired central heating boilers —Specific requirements for the domestic hot water operation of combination boilers of nominal heat input not exceeding 70 kW", or scientific equivalent. 	<p>Accredited certification that the equipment has been tested in accordance with the named standards that apply to the equipment.</p> <p>OR</p> <p>Evidence of official testing by manufacturer or independent test lab carried out according to the principles outlined in the named standards. Test reports should be of the format described in the 'Important Notes to Product Providers' section of this document.</p> <p>Accepted Standards: BS845 for all equipment, and additionally</p> <ul style="list-style-type: none"> • EN304 • EN12953-11 • EN 12952-15 • EN625 <p>as appropriate for the type of boiler.</p> <p>See note on 'Scientific Equivalence' in the 'Important Notes to Product Providers' section at end of this document.</p>

No.	Condition	Supporting Documentation Requirement
9.	Incorporated burners must comply with part 19 "Boiler Controls" eligibility criteria.	Refer to the ACA Boiler Controls supporting documentation requirements.
10.	Standing losses – 2% or less of boiler rated output.	Official and published manufacturer's technical data sheet or brochure that demonstrates the requirements of the condition.

Important Notes to Product Providers

General

There should be a clear link between all supporting documentation supplied and the product being submitted. This will typically take the form of a product code or product name that can be cross referenced between the submitted product and relevant supporting documentation. If product codes / names have been changed since publication of the supporting documentation, then official evidence of this must be provided with the supporting documentation supplied.

Any deviation from these requirements will result in the supporting documentation not being considered adequate for the purposes of demonstrating compliance with the criteria conditions. This will in turn delay the submission and/or result in the product not being considered eligible.

Where the ACA criteria or help documentation reference compliance to appropriate rather than specific standards, the onus is on the product provider to ensure that supporting documentation supplied references recognised standards that apply to the submitted product, i.e. the product must be covered under the scope of a recognised standard.

If any product submitted is later found not to meet the performance or specification criteria, then this product will cease to be considered eligible for the ACA.

Note: When supplying the supporting documentation through the online process you must ensure that the correct page number(s) of the document is referenced when compliance with the relevant condition is being demonstrated. An explanatory note should also be given where more than one page number is referenced.

Test Report

A test report must comprise of the following elements:

An outline of the complete test including introduction, details on test conditions, the specific model details of the product tested, the steps taken in the test, the results, graphical representations, and a conclusion. All documents should be on headed paper and the document should be officially signed off. **All documentation must be in English**, or include adequate translation.

Certification

Where certificates are provided, all tests must be carried out by an organisation that is accredited by a national accreditation body recognised via the European Cooperation for Accreditation (preferred) or the International Accreditation Forum. **All documentation must be in English**, or include adequate translation.

Scientific Equivalence

Some ACA criteria conditions allow for scientifically equivalent tests and/or standards to be used. In the event that a product has not been designed, manufactured or tested to the specific standard named, then documentation relating to an equivalent internationally recognised standard may be used (where the phrase 'Or scientific equivalent' is included in the ACA condition or help documentation). In such applications, the onus will be on the product submitter to demonstrate satisfactory equivalence of the standards. However, submissions which reference such supporting documentation may take longer to process, and if the product provider does not provide satisfactory evidence of equivalence, then the product will not be considered eligible for the ACA. **All documentation must be in English**, or include adequate translation.

Note: Where specific standards are cited in a condition or in the ACA help documentation, then documentation demonstrating that the relevant products have been designed, manufactured or tested to these specific standards is preferred. Scientific equivalence is considered the exception rather than the norm.

Representative testing

Where test information is required for a range of technically similar products (e.g. configurations of one base product) then in exceptional instances a form of representative testing may be utilised once agreed in advance with SEI. Such testing is where only representative products are tested from a technically similar group or range of products. Provided a clear correlation can be demonstrated between the tested product and technically similar non-tested product, and that such a correlation clearly demonstrates the compliance of the non-tested product, representative testing may form an acceptable basis for supporting documentation.

Note: Where representative testing is used for a group or range of products, if the tested or representative product is removed from the list of eligible products then all related products are also removed.